

*Specifier Note:
Insert in the appropriate
place in your Fire Door
specification and
number accordingly.*

AUTOMATIC CLOSURE

Automatic closure thermally controlled by means of 165 degree or 212 degree fusible links. Operating mechanism will be disengaged during automatic closing. Automatic closing rate will be controlled by a governor.

1. Test and reset lever shall be provided to test release function and reset the door from the floor without tools or special training. (Test lever shall be lockable by padlock provided by others.)

Or

1. Time Delay Release Device: UL 864 rated, Fire Sentinel® shall be provided to allow automatic closure from signal of smoke detectors or other fire alarm devices. Provide UL fail safe release device, Model A, or Model B2 with internal battery or for up to 72 hours of power failure support or a combination of B2 and up to three remote release slaves. Fire Sentinel and Fire Minuteman shall both reset from the floor without any tools or special training after the alarm condition has been cleared. Reset device shall be lockable. (Optional floor level keyed test switch.)

©2000 Overhead Door Corporation. All Rights Reserved. A copyright license to reproduce this specification is hereby granted to non-manufacturing architects, engineers and specification writers.