

**The Genuine. The Original.**



SECTION 08 36 13

RESIDENTIAL OVERHEAD DOORS  
DURAFIRM COLLECTION® INSULATED VINYL DOORS – SERIES 870

Display hidden notes to specifier by using 'Tools'/'Options'/'View'/'Hidden Text'. On newer versions of Microsoft Word click on round Windows logo in top left corner, Click on 'Word Options' button at bottom of drop down menu. Click on 'Display' on left menu bar, and check the box for 'Hidden Text'.

**\*\* NOTE TO SPECIFIER \*\* Overhead Door Corp.; Residential Sectional Overhead Door products.**

**This section is based on the products of Overhead Door Corp., which is located at:**  
2501 S. State Hwy. 121 Bus.  
Suite 200  
Lewisville, TX 75067  
Toll Free: (800) 929-3667  
Phone: (469) 549-7100  
Fax: (972) -906-1499  
Web Site: [www.overheaddoor.com](http://www.overheaddoor.com)  
E-mail: [info@overheaddoor.com](mailto:info@overheaddoor.com)

**Overhead Door Corporation pioneered the upward-acting door industry, inventing the first upward-acting door in 1921 and the first electric door opener in 1926. Today, we continue to be the industry leader through the strength of our product innovation, superior craftsmanship and outstanding customer support, underscoring a legacy of quality, expertise and integrity. That's why design and construction professionals specify Overhead Door Corporation products more often than any other brand.**

**PART 1 GENERAL**

1.1 SECTION INCLUDES: Residential Vinyl Overhead Doors.

1.2 RELATED SECTIONS

**\*\* NOTE TO SPECIFIER \*\* Delete any sections below not relevant to this project; add others as required.**

- A. Section 03300 - Cast-In-Place Concrete: Prepared opening in concrete. Execution requirements for placement of anchors in concrete wall construction.
- B. Section 04810 - Unit Masonry Assemblies: Prepared opening in masonry. Execution requirements for placement of anchors in masonry wall construction.
- C. Section 05500 - Metal Fabrications: Steel frame and supports.

- D. Section 06100 - Wood Blocking and Curbing: Rough wood framing and blocking for door opening.
- E. Section 07900 - Joint Sealers: Perimeter sealant and backup materials.
- F. Section 08710 - Door Hardware: Cylinder locks.
- G. Section 09900 - Paints and Coatings: Field painting.
- H. Section 16130 - Raceway and Boxes: Empty conduit from control station to door operator.
- I. Section 16150 - Wiring Connections: Electrical service to door operator.

### 1.3 REFERENCES

**\*\* NOTE TO SPECIFIER \*\* Delete references from the list below that are not actually required by the text of the edited section.**

- A. [ANSI/DASMA 108](#) - Standard Method for Testing Sectional Garage Doors and Rolling Doors: Determination of Structural Performance Under Uniform Static Air Pressure Difference
- B. UL: Underwriters Laboratories, Inc.
- C. ULC: Underwriters Laboratories of Canada.

### 1.4 DESIGN / PERFORMANCE REQUIREMENTS

**\*\* NOTE TO SPECIFIER \*\* Use the applicable building code to determine the actual loading required and edit the following paragraph accordingly. Coordinate with the manufacturer for the selection of doors to meet the required criteria.**

- A. Wind Loads: Design and size components to withstand loads caused by pressure and suction of wind acting normal to plane of wall as calculated in accordance with applicable code.
  - 1. Design pressure of \_\_\_\_\_ lb/sq ft (\_\_\_\_\_ kPa).
- B. Wiring Connections: Requirements for electrical characteristics.
  - 1. 115 volts, single phase, 60 Hz.
- C. Products Requiring Electrical Connection: Listed and classified by Underwriters Laboratories, Inc. acceptable to authority having jurisdiction as suitable for purpose specified.
- D. Single-Source Responsibility: Provide doors, tracks, motors, and accessories from one manufacturer for each type of door. Provide secondary components from source acceptable to manufacturer of primary components.

### 1.5 SUBMITTALS

- A. Submit under provisions of Section 01300.
- B. Product Data: Manufacturer's data sheets on each product to be used, including:
  - 1. Preparation instructions and recommendations.
  - 2. Storage and handling requirements and recommendations.
  - 3. Installation methods.

- C. Shop Drawings: Indicate plans and elevations including opening dimensions and required tolerances, connection details, anchorage spacing, hardware locations, and installation details.

**\*\* NOTE TO SPECIFIER \*\* Delete selection samples if colors have already been selected.**

- D. Selection Samples: For each finish product specified, two complete sets of color chips representing manufacturer's full range of available colors and patterns.
- E. Verification Samples: For each finish product specified, two samples, minimum size 6 inches (150 mm) square, representing actual product, color, and patterns.
- F. Manufacturer's Certificates: Certify products meet or exceed specified requirements.
- G. Operation and Maintenance Data.

## 1.6 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Company specializing in manufacturing products specified in this section with minimum five years documented experience.
- B. Installer Qualifications: Authorized representative of the manufacturer with minimum five years documented experience.
- C. Products Requiring Electrical Connection: Listed and classified by Underwriters Laboratories, Inc. acceptable to authority having jurisdiction as suitable for purpose specified.

## 1.7 DELIVERY, STORAGE, AND HANDLING

- A. Store products in manufacturer's unopened labeled packaging until ready for installation.
- B. Protect materials from exposure to moisture until ready for installation.
- C. Store materials in a dry, ventilated weathertight location.
- D. Store and dispose of solvent-based materials, and materials used with solvent-based materials, in accordance with requirements of local authorities having jurisdiction.

## 1.8 WARRANTY

- A. Durafirm Collection 870 Series Insulated. Warranty: 15 year limited against flaking, chipping, cracking of vinyl skin, 5 year against color fading of the vinyl skin and all other components for 1 year.

## PART 2 PRODUCTS

### 2.1 MANUFACTURERS

- A. Acceptable Manufacturer: Overhead Door Corp., 2501 S. State Hwy. 121 Bus., Suite 200, Lewisville, TX 75067. ASD. Tel. Toll Free: (800) 929-3667. Phone: (469) 549-7100. Fax: (972) 906-1499. Web Site: [www.overheaddoor.com](http://www.overheaddoor.com). E-mail: [info@overheaddoor.com](mailto:info@overheaddoor.com).

**\*\* NOTE TO SPECIFIER \*\* Delete one of the following two paragraphs; coordinate with requirements of Division 1 section on product options and substitutions.**

- B. Substitutions: Not permitted.
- C. Requests for substitutions will be considered in accordance with provisions of Section 01600.

## 2.2 RESIDENTIAL VINYL OVERHEAD DOORS

**\*\* NOTE TO SPECIFIER \*\* Durafirm Collection 870 Series Insulated Vinyl with Wood Grain Finish Doors are available up to a maximum width of 18 feet and a maximum height of 14 feet.**

- A. Insulated Vinyl Sectional Overhead Doors: Durafirm Collection 870 Series Insulated Vinyl Doors by Overhead Door Corporation.
  - 1. Door Assembly: Exterior skin material is .052 inch (1.32 mm) thick, color-fast, precision wood grain embossed vinyl which is bonded with the structural polyurethane core to the 22 gauge galvanized steel C-Channel internal struts. Fabricated with EPDM seals between sections.

**\*\* NOTE TO SPECIFIER \*\* Consult with manufacturer for available configuration sizes.**

- a. Size: As indicated on the Drawings.
- b. Panel Thickness: 1-3/8 inch (34.93 mm).
- c. Panel Style: Tongue and groove.
  - 1) Short Panel, 870 Series.
  - 2) V5 Panel, 872 Series.
- d. Exterior Skin: .052 inch (1.32 mm), color-fast, precision wood grain embossed vinyl skin.
- e. Interior Skin: .030 inch (.76 mm) thick, white embossed vinyl interior backer skin.
- f. Insulation: Foamed-in-place polyurethane.
- g. Thermal Values: R-value of 11.7.

**\*\* NOTE TO SPECIFIER \*\* Coordinate with the manufacturer for the selection of doors to meet the required criteria.**

- h. Windload Design: Provide to meet the Design/Performance requirements specified.

**\*\* NOTE TO SPECIFIER \*\* Select window options required from the following paragraphs. Delete the paragraphs not required or delete entirely if windows are not required.**

- i. Window Design:
  - 1) Window Location: Top section.
  - 2) Glass Type: 1/8 inch (3 mm) double strength
    - (a) Clear Insulated.
    - (b) Clear Non-insulated.
    - (c) Frosted Insulated.
    - (d) Frosted Non-insulated.

**\*\* NOTE TO SPECIFIER \*\* Select Decorative Window Style as required from the following paragraphs and delete the ones not required.**

- 3) Decorative Window Style:
  - (a) Full Vision (Short panel).
  - (b) Cathedral 1.
  - (c) Ruston 1.
  - (d) Stockton 1.
  - (e) Williamsburg 4 (4 piece).
  - (f) Williamsburg 8 (8 piece).

**\*\* NOTE TO SPECIFIER \*\* Select glass type required from the following paragraphs and delete the ones not required.**

- (a) Glass: Clear.

- (b) Glass: Clear Insulated.
  - (c) Glass: Obscure.
  - (d) Glass: Obscure Insulated.
2. Glass: Insulated Satin Etched, Finish/Color: Through-and-through color PVC construction; UV-resistant resin.

**\*\* NOTE TO SPECIFIER \*\* Select color required from the following paragraphs and delete the ones not required.**

- a. Glacier White.
  - b. Monterey Sand.
  - c. Adobe Cream.
  - d. Cape Cod Gray.
3. Hardware: Standard hinges.
4. Spring: Torsion spring assembly.
5. Lock:
- a. Interior mounted slide lock.

**\*\* NOTE TO SPECIFIER \*\* Include the following optional paragraph if required and delete if not required.**

- b. Optional keyed lock.
6. Weatherstripping: Co-extruded PVC bulb-type strip at bottom.
7. Track: Provide track as recommended by manufacturer to suit loading required and clearances available.
8. Standard rollers.

**\*\* NOTE TO SPECIFIER \*\* Select one of the following operation paragraphs and delete the one not required.**

- 9. Manual Operation.
- 10. Electric Openers.

## **PART 3 EXECUTION**

### **3.1 EXAMINATION**

- A. Do not begin installation until openings and substrates have been properly prepared.
- B. Verify wall openings are ready to receive work and opening dimensions and tolerances are within specified limits.
- C. Verify electric power is available and of correct characteristics.
- D. If preparation is the responsibility of another installer, notify Architect of unsatisfactory preparation before proceeding.

### **3.2 PREPARATION**

- A. Clean surfaces thoroughly prior to installation.
- B. Prepare surfaces using the methods recommended by the manufacturer for achieving the best result for the substrate under the project conditions.

### **3.3 INSTALLATION**

- A. Install overhead doors, track and openers in accordance with approved shop drawings and the manufacturer's printed instructions.
- B. Coordinate installation with adjacent work to ensure proper clearances and allow for maintenance.

- C. Anchor assembly to wall construction and building framing without distortion or stress.
- D. Securely brace door tracks suspended from structure. Secure tracks to structural members only.
- E. Fit and align door assembly including hardware.

**\*\* NOTE TO SPECIFIER \*\* Include the following paragraph for power operated doors. Delete if not required.**

- F. Coordinate installation of electrical service with Section 16150.

#### 3.4 CLEANING AND ADJUSTING

- A. Adjust door assembly to smooth operation and in full contact with weatherstripping.
- B. Clean doors, frames and glass.
- C. Remove temporary labels and visible markings.

#### 3.5 PROTECTION

- A. Do not permit construction traffic through overhead door openings after adjustment and cleaning.
- B. Protect installed products until completion of project.
- C. Touch-up, damaged coatings and finishes and repair minor damage before Substantial Completion.

END OF SECTION