## The Genuine. The Original.



#### SECTION 08330

#### **ROLLING SHUTTER DOORS**

#### ALLURA® MODEL 653

Display hidden notes to specifier by using "Tools"/"Options"/"View"/"Hidden Text".

\*\* NOTE TO SPECIFIER \*\* Overhead Door Corporation; rolling service door products.

This section is based on the products of Overhead Door Corporation, which is located at:

2501 S. State Hwy. 121

Suite 200

Lewisville, TX 75067 Toll Free: (800) 275-3290 Phone: (469) 549-7100 Fax: (972) -906-1499

Web Site: www.overheaddoor.com E-mail: <a href="mailto:info@overheaddoor.com">info@overheaddoor.com</a>

Overhead Door Corporation pioneered the upward-acting door industry, inventing the first upward-acting door in 1921 and the first electric door opener in 1926. Today, we continue to be the industry leader through the strength of our product innovation, superior craftsmanship and outstanding customer support, underscoring a legacy of quality, expertise and integrity. That's why design and construction professionals specify Overhead Door Corporation products more often than any other brand.

The section includes Overhead Door Corporation's rolling service door product line ensures that your project specifications will be met with ease and style. Ideal for situations where sideroom and headroom are at a premium, our upward-coiling service doors fit openings up to 1500 SF and are available with the industry's widest array of slat profiles, curtain materials and colors, offering a virtually endless array of options to satisfy both aesthetic considerations and working requirements.

This specification also includes RapidSlat® advanced performance rolling service doors that are an extension of the rolling steel product line and provides customers with speed and product longevity. It includes the same general construction as Overhead Door's rolling steel line with enhancements to provide increased speed, security and durability. These innovations include: Maximum performance and functionality with minimum maintenance requirements; Five-year limited warranty on door system.

## PART 1 GENERAL

- 1.1 SECTION INCLUDES
- \*\* NOTE TO SPECIFIER \*\* Delete items below not required for project.
  - A. Rolling security shutters.

#### 1.2 RELATED SECTIONS

\*\* NOTE TO SPECIFIER \*\* Delete any sections below not relevant to this project; add others as required.

- A. Section 05500 Metal Fabrications: Support framing and framed opening.
- B. Section 06200 Finish Carpentry: Wood jamb and head trim.
- C. Section 08333 Security Grilles.
- D. Section 08710 Door Hardware: Product Requirements for cylinder core and keys.
- E. Section 09900 Painting: Field applied finish.
- F. Section 16130 Raceway and Boxes: Conduit from electric circuit to door operator and from door operator to control station.
- G. Section 16150 Wiring Connections: Power to disconnect.

#### 1.3 REFERENCES

\*\* NOTE TO SPECIFIER \*\* Delete references from the list below that are not actually required by the text of the edited section.

- A. ANSI/DASMA 108 American National Standards Institute Standard Method For Testing Sectional Garage Doors And Rolling Doors: Determination Of Structural Performance Under Uniform Static Air Pressure Difference.
- B. NFRC 102 Test Procedure for Measuring the Steady-State Thermal Transmittance of Fenestration Systems.
- C. ASTM E 90 Standard Test Method for Laboratory Measurement of Airborne Sound Transmission Loss of Building Partitions and Element.
- D. ASTM E 330 Standard Test Method for Structural Performance of Exterior Windows, Doors, Skylights and Curtain Walls by Uniform Static Air Pressure Difference.
- E. ASTM A 653 Standard Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process.
- F. ASTM A 666 Standard Specification for Austenitic Stainless Steel Sheet, Strip, Plate, and Flat Bar.
- G. ASTM A 924 Standard Specification for General Requirements for Steel Sheet, Metallic-Coated by the Hot-Dip Process.
- H. ASTM B 221 Standard Specification for Aluminum and Aluminum-Alloy Extruded Bars, Rods, Wire, Profiles, and Tubes.
- I. NEMA 250 Enclosures for Electrical Equipment (1000 Volts Maximum).
- NEMA MG 1 Motors and Generators.

## 1.4 DESIGN / PERFORMANCE REQUIREMENTS

- A. Single-Source Responsibility: Provide doors, tracks, motors, and accessories from one manufacturer for each type of door. Provide secondary components from source acceptable to manufacturer of primary components.
- B. Products Requiring Electrical Connection: Listed and classified by Underwriters Laboratories, Inc. acceptable to authority having jurisdiction as suitable for purpose specified.

#### 1.5 SUBMITTALS

- A. Submit under provisions of Section 01300.
- B. Product Data: Manufacturer's data sheets on each product to be used, including:
  - 1. Preparation instructions and recommendations.
  - 2. Storage and handling requirements and recommendations.
  - 3. Details of construction and fabrication.
  - Installation instructions.
- C. Shop Drawings: Include detailed plans, elevations, details of framing members, anchoring methods, required clearances, hardware, and accessories. Include relationship with adjacent construction.

## \*\* NOTE TO SPECIFIER \*\* Delete selection samples if colors have already been selected.

- D. Selection Samples: For each finish product specified, two complete sets of color chips representing manufacturer's full range of available colors and patterns.
- E. Verification Samples: For each finish product specified, two samples, minimum size 6 inches (150 mm) long, representing actual product, color, and patterns.
- F. Manufacturer's Certify products meet or exceed specified requirements.
- G. Operation and Maintenance Data: Submit lubrication requirements and frequency, and periodic adjustments required.

#### 1.6 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Company specializing in performing Work of this section with a minimum of five years experience in the fabrication and installation of security closures.
- B. Installer Qualifications: Installer Qualifications: Company specializing in performing Work of this section with minimum three years and approved by manufacturer.
- \*\* NOTE TO SPECIFIER \*\* Include a mock-up if the project size and/or quality warrant taking such a precaution. The following is one example of how a mock-up on a large project might be specified. When deciding on the extent of the mock-up, consider all the major different types of work on the project.
  - C. Mock-Up: Provide a mock-up for evaluation of surface preparation techniques and application workmanship.
    - 1. Finish areas designated by Architect.
    - 2. Do not proceed with remaining work until workmanship, color, and sheen are approved by Architect.
    - 3. Refinish mock-up area as required to produce acceptable work.

## 1.7 DELIVERY, STORAGE, AND HANDLING

- A. Store products in manufacturer's unopened packaging until ready for installation.
- B. Protect materials from exposure to moisture. Do not deliver until after wet work is complete and dry.
- C. Store materials in a dry, warm, ventilated weathertight location.

#### 1.8 PROJECT CONDITIONS

A. Maintain environmental conditions (temperature, humidity, and ventilation) within limits recommended by manufacturer for optimum results. Do not install products under environmental conditions outside manufacturer's absolute limits.

#### 1.9 COORDINATION

A. Coordinate Work with other operations and installation of adjacent materials to avoid damage to installed materials.

#### 1.10 WARRANTY

- \*\* NOTE TO SPECIFIER \*\* Include the following warranty paragraph for Model 600, 610, 620, 625 or 627 rolling service doors and Model 653 shutters not provided as a system with operators. Delete if not applicable.
  - A. Warranty: Manufacturer's limited door system warranty for 2 years for all parts and components.
- \*\* NOTE TO SPECIFIER \*\* Include the following Optional PowderGuard Finish warranty paragraph if included for the Door(s) specified. Delete if not applicable.
  - B. PowderGuard Finish
- \*\* NOTE TO SPECIFIER \*\* Include the one of the following PowderGuard Finish warranty paragraphs for the finish specified. Delete if not applicable.
  - 1. PowderGuard Premium Applied to curtain, guides, bottom bar, headplates: Manufacturer's limited Premium Finish warranty for 2 years.
  - 2. PowderGuard Zinc Base Coat applied to guides, bottom bar, headplates plus PowderGuard Premium applied to curtain and top coat for guides, bottom bar, headplates: Manufacturer's limited Zinc Finish warranty for 4 years.
  - 3. PowderGuard Textured: Applied to curtain, guides, bottom bar, headplates: Manufacturer's limited Textured Finish warranty for 3 years.
  - 4. PowderGuard Zinc Base Coat applied to guides, bottom bar, headplates plus PowderGuard Textured applied to curtain and top coat for guides, bottom bar, headplates: Manufacturer's limited Zinc Finish warranty for 4 years.
  - 5. PowderGuard Max: Applied to curtain, guides, bottom bar, headplates: Manufacturer's limited Max Finish warranty for 5 years.

## PART 2 PRODUCTS

#### 2.1 MANUFACTURERS

A. Acceptable Manufacturer: Overhead Door Corporation, 2501 S. State Hwy. 121, Suite 200, Lewisville, TX 75067. ASD. Tel. Toll Free: (800) 275-3290. Phone: (469) 549-7100. Fax: (972) 906-1499. Web Site: <a href="www.overheaddoor.com">www.overheaddoor.com</a>. E-mail: <a href="mailto:info@overheaddoor.com">info@overheaddoor.com</a>.

- \*\* NOTE TO SPECIFIER \*\* Delete one of the following two paragraphs; coordinate with requirements of Division 1 section on product options and substitutions.
  - B. Substitutions: Not permitted.
  - Requests for substitutions will be considered in accordance with provisions of Section 01600.

#### 2.2 ROLLING SECURITY SHUTTERS

- \*\* NOTE TO SPECIFIER \*\* Security Shutter Model 653 is not wind load rated. This door is ideal for interior applications or exterior applications where wind load is not required. Available in a maximum height up to 14 feet and a maximum width up to 20 feet. Contact the manufacturer for additional information.
  - A. Aluminum Light Duty Shutter: Overhead Door Corporation, Model 653.
    - 1. Wall Mounting Condition:
- \*\* NOTE TO SPECIFIER \*\* Select one of the following two paragraphs and delete the one not required.
  - a. Face-of-wall mounting.
  - b. Between jambs mounting.
  - 2. Curtain: Interlocking extruded aluminum slats constructed of .05 inch aluminum. Nickel plated, steel screws and end locks to retain curtain within guides and prevent lateral movement. Over 16 feet wide will come standard with plastic roller retainers to strengthen curtain.
  - 3. Fenestration/Perforation:
- \*\* NOTE TO SPECIFIER \*\* Select one of the following paragraphs and delete those not required.
  - a. Open fenestration 1 inch by 1 inch; 0.5 inch uniformly spaced openings; full curtain.
  - b. Perforation full curtain.
  - c. Partial open fenestration, 1 inch by 1 inch; 0.5 inch uniformly spaced openings; Height of curtain segment to be fenestrated as indicated on the Drawings.
  - d. Partial perforation, height of curtain segment to be perforated as indicated on the Drawings.
  - 4. Curtain and Hood Finish:
- \*\* NOTE TO SPECIFIER \*\* Select one of the following for PowderGuard Premium powder coat and delete the ones not required. PowderGuard Premium powder coat finish is standard in the four colors listed.
  - a. Powder Coat: PowderGuard Premium
    - 1) Silver powder coat to match look of clear anodized aluminum.
    - 2) Bronze powder coat to match look of bronze anodized.
    - 3) White.
    - 4) Almond.
    - 5) PowderGuard Premium color as selected by the Architect.
  - 5. Bottom Bar and Locking:
- \*\* NOTE TO SPECIFIER \*\* Select from the following paragraphs and delete the ones not required.
  - Aluminum compact bottom bar with vinyl bulb seal with coil side left and right slide locks. Powder coat to match curtain color selection. (standard).
  - b. Aluminum compact bottom bar with vinyl bulb seal with padlock-able non-coil side left and right slide locks. Powder coat to match curtain color selection.

- c. Tubular aluminum cylinder locking bottom bar with weatherstrip.

  Requires 1.5 inch by 3 inch wall tubes for face of wall mount.
- Locking doors with tube motor shall be provided with interlock micro switch.
- e. Aluminum compact bottom bar with vinyl bulb seal; non-locking.
- f. Step angle attachment option.
- 6. Guides: Extruded aluminum channels with continuous PVC wear strips. Powder coat: color to match curtain.
- 7. Brackets: Steel plate to support counterbalance, curtain and hood. Powder coat to match curtain color selection.
- 8. Hood: Aluminum 2 piece square hood silver powder coated to match curtain color selection. Provide with intermediate support brackets as required. Hood with brackets; box sized to match manufacturer's recommendation based on door height.
- 9. Counterbalance: Extruded aluminum barrel housing counterbalance spring assembly.
- 10. Operation:
- \*\* NOTE TO SPECIFIER \*\* Select one of the following operation paragraphs and delete the ones not required.
  - a. Manual push up.
  - b. Crank operation.
  - c. Electric tube motor with crank for emergency egress manual override.
- \*\* NOTE TO SPECIFIER \*\* Include the following paragraph is electric motor operation is required and delete if not required.
  - 11. Electric Motor Operation: Provide UL listed electric operator, size as recommended by manufacturer:
    - a. Operator Controls:
      - 1) Double throw hard wired wall switch.

## PART 3 EXECUTION

#### 3.1 EXAMINATION

- A. Verify opening sizes, tolerances and conditions are acceptable.
- B. Examine conditions of substrates, supports, and other conditions under which this work is to be performed.
- C. If substrate preparation is the responsibility of another installer, notify Architect of unsatisfactory preparation before proceeding.

#### 3.2 PREPARATION

- A. Clean surfaces thoroughly prior to installation.
- B. Prepare surfaces using the methods recommended by the manufacturer for achieving the best result for the substrate under the project conditions.

#### 3.3 INSTALLATION

- A. Install in accordance with manufacturer's instructions.
- B. Use anchorage devices to securely fasten assembly to wall construction and building framing without distortion or stress.

- C. Securely and rigidly brace components suspended from structure. Secure guides to structural members only.
- D. Fit and align assembly including hardware; level and plumb, to provide smooth operation.

# \*\* NOTE TO SPECIFIER \*\* Select the following paragraph for electric operation of coiling doors and delete if not required.

- E. Coordinate installation of electrical service with Section 16150. Complete wiring from disconnect to unit components.
- F. Coordinate installation of sealants and backing materials at frame perimeter as specified in Section 07900.
- G. Install perimeter trim and closures.
- H. Instruct Owner's personnel in proper operating procedures and maintenance schedule.

#### 3.4 ADJUSTING

- A. Test for proper operation and adjust as necessary to provide proper operation without binding or distortion.
- B. Adjust hardware and operating assemblies for smooth and noiseless operation.

#### 3.5 CLEANING

- A. Clean curtain and components using non-abrasive materials and methods recommended by manufacturer.
- B. Remove labels and visible markings.
- C. Touch-up, repair or replace damaged products before Substantial Completion.

#### 3.6 PROTECTION

A. Protect installed products until completion of project.

**END OF SECTION**