



SECTION 08 33 00
SECURITY GRILLES
671 SERIES with EEG UPCOILING SECURITY GRILLE

Display hidden notes to specifier by using 'Tools'/'Options'/'View'/'Hidden Text'. On newer versions of Microsoft Word click on round Windows logo in top left corner, Click on 'Word Options' button at bottom of drop down menu. Click on 'Display' on left menu bar, and check the box for 'Hidden Text'.

PART 1 GENERAL

1.1 SECTION INCLUDES

**** NOTE TO SPECIFIER ** Delete items below not required for project.**

- A. Upcoiling Security Grilles, manually operated.
- B. Upcoiling Security Grilles, power operated.

1.2 RELATED SECTIONS

**** NOTE TO SPECIFIER ** Delete any sections below not relevant to this project; add others as required.**

- A. Section 05500 - Metal Fabrications: Support framing and framed opening.
- B. Section 06200 - Finish Carpentry: Wood jamb and head trim.
- C. Section 08332 - Overhead Coiling Counter Doors.
- D. Section 08710 - Door Hardware: Product Requirements for cylinder core and keys.
- E. Section 16130 - Raceway and Boxes: Conduit from electric circuit to grille operator and from grille operator to control station.
- F. Section 16150 - Wiring Connections: Power to disconnect.

1.3 REFERENCES

**** NOTE TO SPECIFIER ** Delete references from the list below that are not actually required by the text of the edited section.**

- A. [ASTM A 653](#) - Standard Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process.
- B. [ASTM A 666](#) - Standard Specification for Austenitic Stainless Steel Sheet, Strip, Plate, and Flat Bar.
- C. [ASTM A 924](#) - Standard Specification for General Requirements for Steel Sheet, Metallic-Coated by the Hot-Dip Process.
- D. [ASTM B 221](#) - Standard Specification for Aluminum and Aluminum-Alloy Extruded Bars, Rods, Wire, Profiles, and Tubes.
- E. [NEMA 250](#) - Enclosures for Electrical Equipment (1000 Volts Maximum).

- F. [NEMA ICS 2](#) - Industrial Control and Systems: Controllers, Contactors, and Overload Relays, Rated Not More Than 2000 Volts AC or 750 Volts DC.
- G. [NEMA MG 1](#) - Motors and Generators.

1.4 SUBMITTALS

- A. Submit under provisions of Section 01300.
- B. Product Data: Manufacturer's data sheets on each product to be used, including:
 - 1. Preparation instructions and recommendations.
 - 2. Storage and handling requirements and recommendations.
 - 3. Installation methods.
- C. Shop Drawings: Include detailed plans, elevations, details of framing members, required clearances, anchors, and accessories. Include relationship with adjacent materials.

**** NOTE TO SPECIFIER ** Delete selection samples if colors have already been selected.**

- D. Selection Samples: For each finish product specified, two complete sets of color chips representing manufacturer's full range of available colors and patterns.
- E. Verification Samples: For each finish product specified, two samples, representing actual product, color, and patterns.
- F. Manufacturer's Certificates: Certify products meet or exceed specified requirements.

1.5 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Company specializing in performing Work of this section with a minimum of five years experience in the fabrication and installation of security closures.
- B. Installer Qualifications: Company specializing in performing Work of this section with minimum three years and approved by manufacturer.

**** NOTE TO SPECIFIER ** Include a mock-up if the project size and/or quality warrant taking such a precaution. The following is one example of how a mock-up on a large project might be specified. When deciding on the extent of the mock-up, consider all the major different types of work on the project.**

- C. Mock-Up: Provide a mock-up for evaluation of surface preparation techniques and application workmanship.
 - 1. Install in areas designated by Architect.
 - 2. Do not proceed with remaining work until workmanship and installation is approved by Architect.
 - 3. Refinish mock-up area as required to produce acceptable work.

1.6 DELIVERY, STORAGE, AND HANDLING

- A. Store products in manufacturer's unopened packaging until ready for installation.
- B. Protect materials from exposure to moisture. Do not deliver until after wet work is complete and dry.
- C. Store materials in a dry, warm, ventilated weathertight location.

1.7 COORDINATION

- A. Coordinate Work with other operations and installation of adjacent finish materials to avoid damage to installed materials.

PART 2 PRODUCTS

2.1 MANUFACTURERS

- A. Acceptable Manufacturer: Overhead Door Corp., 2501 S. State Hwy. 121, Suite 200, Lewisville, TX 75067. ASD. Tel. Toll Free: (800) 275-3290. Phone: (469) 549-7100. Fax: (972) 906-1499. Web Site: www.overheaddoor.com. E-mail: info@overheaddoor.com.

**** NOTE TO SPECIFIER ** Delete one of the following two paragraphs; coordinate with requirements of Division 1 section on product options and substitutions.**

- B. Substitutions: Not permitted.
- C. Requests for substitutions will be considered in accordance with provisions of Section 01600.

2.2 UPCOILING SECURITY GRILLES

- A. Overhead Coiling Metal Grilles: Overhead Door Corporation Model 671 with an option for Manual Emergency Release for power operated doors.
 - 1. Curtain: Horizontal 5/16 inch (7.8 mm) diameter rods with network of vertically interlocking links to form a pattern. Bottom bar extruded aluminum tubular shape.

a. Material:

**** NOTE TO SPECIFIER ** Select the material required from the following paragraphs and delete the paragraph not required.**

- 1) Galvanized Steel.
- 2) Stainless Steel.

b. Vertical Rod Spacing:

**** NOTE TO SPECIFIER ** Select the spacing required from the following paragraphs and delete the paragraph not required.**

- 1) 2 inches (51 mm) on center.
- 2) 1-1/2 inches (38 mm) on center.

c. Pattern:

**** NOTE TO SPECIFIER ** Select the pattern required from the following paragraphs and delete the paragraphs not required.**

- 1) Straight lattice; horizontal spacing 3 inches (76 mm) on center.
- 2) Straight lattice; horizontal spacing 6 inches (152 mm) on center.
- 3) Straight lattice; horizontal spacing 9 inches (228 mm) on center.
- 4) Brick pattern; horizontal spacing 4-1/2 inches (114 mm) on center.
- 5) Infill Panels: Lexan panel in straight lattice pattern 12 inches on center.

2. Finish:

**** NOTE TO SPECIFIER ** Select the finish required from the following paragraphs and delete the paragraph not required.**

- a. Stainless Steel: No. #4 finish.
- b. Stainless Steel: No. #2B finish.
- c. Galvanized Steel: Rust inhibitive primer.

- d. Prime all non-galvanized, exposed ferrous surfaces with black powder coat finish.
- 3. Bottom Bar:
 - a. Double angle steel bottom bar.
 - b. Double angle stainless steel bottom bar.
- 4. Guides:
 - a. Extruded aluminum shapes with retainer grooves and continuous silicone treated wool-pile strips or PVC inserts to reduce noise and assist operation.

**** NOTE TO SPECIFIER ** Select the guides mounting required from the following paragraphs and delete the paragraph not required.**

- b. Guides face mounted on adjacent construction.
- c. Guides free standing with tubular steel support frames supplied with grilles.
- 5. Brackets: Minimum 3/16 inch (4.8 mm) steel to support barrel, counterbalance and hood as applicable.
- 6. Counterbalance: Helical torsion spring type housed in a steel tube or pipe barrel, supporting the curtain with maximum deflection of 0.03 inches per foot of span. Counterbalance adjustable by means of an adjusting tension wheel.

**** NOTE TO SPECIFIER ** Select the hood type required from the following paragraphs and delete the paragraphs not required. Delete if not required for installation above ceiling.**

- 7. Hood:
 - a. Galvanized steel, 24 gauge (6 mm).
 - b. Primed steel, 24 gauge (6 mm).
 - c. Stainless Steel: No. #4 finish.
 - d. Stainless Steel: No. #2B finish.

**** NOTE TO SPECIFIER ** Select manual or electric operation as required from the following paragraphs and delete the paragraphs not required.**

- 8. Manual Operation:

**** NOTE TO SPECIFIER ** Select the manual operation required from the following paragraphs and delete the paragraphs not required.**

- a. Push up.
- b. Chain hoist.
- c. Crank.
- 9. Electric Motor Operation: Provide UL listed electric operator, size as recommended by manufacturer to move door in either direction at not less than 2/3 foot nor more than 1 foot per second.

**** NOTE TO SPECIFIER ** Select the edge protection required from the following paragraphs and delete the paragraph not required.**

- a. Sensing Edge Protection:
 - 1) Pneumatic sensing edge.
 - 2) Electric sensing edge.
- b. Operator Controls: Control stations with open, close, and stop functions.

**** NOTE TO SPECIFIER ** Select the operation required from the following paragraphs and delete the paragraphs not required.**

- 1) Push-button operation.
- 2) Key operation.
- 3) Push-button and key operation.

**** NOTE TO SPECIFIER ** Select the control mounting type required from the following paragraphs and delete the paragraph not required.**

- 4) Surface mounting.
- 5) Flush mounting.

**** NOTE TO SPECIFIER ** Select the location required from the following paragraphs and delete the paragraphs not required.**

- 6) For interior location.

- 7) For exterior location.
- 8) For both interior and exterior location.

**** NOTE TO SPECIFIER ** Electric operated doors are available with Electric Motor Operation or Electric Motor with Manual Egress lever. Select the emergency egress device from the following paragraph and delete if not required.**

- c. Emergency Egress: Provide code compliant emergency egress system that automatically unlocks and manually releases grille part way to permit passage, even if power is not available.

**** NOTE TO SPECIFIER ** Select the special operation type required from the following paragraphs and delete the paragraphs not required. Delete entirely if special operation is not required.**

- d. Special Operation:
 - 1) Vehicle detector operation.
 - 2) Radio control operation.
 - 3) Card reader control.
 - 4) Photocell operation.
 - 5) Door timer operation.
 - 6) Commercial light package.
 - 7) Explosion and dust ignition proof control wiring.

10. Locking:

**** NOTE TO SPECIFIER ** Select the locking type required from the following paragraphs and delete the paragraphs not required.**

- a. Cremone lock.
- b. Chain keeper locks for chain hoist operation.
- c. Cylinder lock for electric operation with interlock switch.
- d. Thumb turns.

PART 3 EXECUTION

3.1 EXAMINATION

- A. Verify opening sizes, tolerances and conditions are acceptable.
- B. Examine conditions of substrates, supports, and other conditions under which this work is to be performed.
- C. If substrate preparation is the responsibility of another installer, notify Architect of unsatisfactory preparation before proceeding.

3.2 PREPARATION

- A. Clean surfaces thoroughly prior to installation.
- B. Prepare surfaces using the methods recommended by the manufacturer for achieving the best result for the substrate under the project conditions.

3.3 INSTALLATION

- A. Install in accordance with manufacturer's instructions.
- B. Use anchorage devices to securely fasten assembly to wall construction and building framing without distortion or stress.
- C. Securely and rigidly brace components suspended from structure. Secure guides to structural members only.

- D. Fit and align assembly including hardware; level and plumb, to provide smooth operation.

**** NOTE TO SPECIFIER ** Select the following paragraph for electric operation of grilles and delete if not required.**

- E. Coordinate installation of electrical service with Section 16150. Complete wiring from disconnect to unit components.
- F. Coordinate installation of sealants and backing materials at frame perimeter as specified in Section 07900.
- G. Install perimeter trim and closures.

3.4 ADJUSTING

- A. Test security grilles for proper operation and adjust as necessary to provide proper operation without binding or distortion.
- B. Adjust hardware and operating assemblies for smooth and noiseless operation.

3.5 CLEANING

- A. Clean curtain and components using non-abrasive materials and methods recommended by manufacturer.
- B. Remove labels and visible markings.
- C. Touch-up, repair or replace damaged products before Substantial Completion.

3.6 PROTECTION

- A. Protect installed products until completion of project.

END OF SECTION