



SECTION 08 36 00
SECTIONAL OVERHEAD DOORS
THERMACORE® AP MODEL 850 INSULATED STEEL DOORS

Display hidden notes to specifier by using 'Tools'/'Options'/'View'/'Hidden Text'. On newer versions of Microsoft Word click on round Windows logo in top left corner, Click on 'Word Options' button at bottom of drop down menu. Click on 'Display' on left menu bar, and check the box for 'Hidden Text'.

PART 1 GENERAL

1.1 SECTION INCLUDES

**** NOTE TO SPECIFIER ** Delete items below not required for project.**

- A. Insulated Sectional Overhead Doors.
- B. Electric Operators and Controls.
- C. Operating Hardware, tracks, and support.

1.2 RELATED SECTIONS

**** NOTE TO SPECIFIER ** Delete any sections below not relevant to this project; add others as required.**

- A. Section 03300 - Cast-In-Place Concrete: Prepared opening in concrete. Execution requirements for placement of anchors in concrete wall construction.
- B. Section 04810 - Unit Masonry Assemblies: Prepared opening in masonry. Execution requirements for placement of anchors in masonry wall construction.
- C. Section 05500 - Metal Fabrications: Steel frame and supports.
- D. Section 06114 - Wood Blocking and Curbing: Rough wood framing and blocking for door opening.
- E. Section 07900 - Joint Sealers: Perimeter sealant and backup materials.
- F. Section 08710 - Door Hardware: Cylinder locks.
- G. Section 09900 - Paints and Coatings: Field painting.
- H. Section 11150 - Parking Control Equipment: Remote door control.
- I. Section 16130 - Raceway and Boxes: Empty conduit from control station to door operator.
- J. Section 16150 - Wiring Connections: Electrical service to door operator.

1.3 REFERENCES

**** NOTE TO SPECIFIER ** Delete references from the list below that are not actually required by the text of the edited section.**

- A. ANSI/DASMA 102 - American National Standard Specifications for Sectional Overhead Type Doors.

1.4 DESIGN / PERFORMANCE REQUIREMENTS

**** NOTE TO SPECIFIER ** Use the applicable building code to determine the actual loading required and edit the following paragraph accordingly. Coordinate with the manufacturer for the selection of doors to meet the required criteria.**

- A. Wind Loads: Design and size components to withstand loads caused by pressure and suction of wind acting normal to plane of wall as calculated in accordance with applicable code.
 - 1. Design pressure of _____ lb/sq ft (_____ kPa).

**** NOTE TO SPECIFIER ** Edit the following paragraph for power operators as required. Delete if not required.**

- B. Wiring Connections: Requirements for electrical characteristics.
 - 1. 115 volts, single phase, 60 Hz.
 - 2. 230 volts, single phase, 60 Hz.
 - 3. 230 volts, three phase, 60 Hz.
 - 4. 460 volts, three phase, 60 Hz.
- C. Single-Source Responsibility: Provide doors, tracks, motors, and accessories from one manufacturer for each type of door. Provide secondary components from source acceptable to manufacturer of primary components.

1.5 SUBMITTALS

- A. Submit under provisions of Section 01300.
- B. Product Data: Manufacturer's data sheets on each product to be used, including:
 - 1. Preparation instructions and recommendations.
 - 2. Storage and handling requirements and recommendations.
 - 3. Installation methods.
- C. Shop Drawings: Indicate plans and elevations including opening dimensions and required tolerances, connection details, anchorage spacing, hardware locations, and installation details.
- D. Manufacturer's Certificates: Certify products meet or exceed specified requirements.
- E. Operation and Maintenance Data.

1.6 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Company specializing in manufacturing products specified in this section with minimum five years documented experience.
- B. Installer Qualifications: Authorized representative of the manufacturer with minimum five years documented experience.
- C. Products Requiring Electrical Connection: Listed and classified by Underwriters Laboratories, Inc. acceptable to authority having jurisdiction as suitable for purpose specified.

1.7 DELIVERY, STORAGE, AND HANDLING

- A. Store products in manufacturer's unopened labeled packaging until ready for installation.
- B. Protect materials from exposure to moisture until ready for installation.

- C. Store materials in a dry, ventilated weathertight location.

1.8 PROJECT CONDITIONS

- A. Pre-Installation Conference: Convene a pre-installation conference just prior to commencement of field operations, to establish procedures to maintain optimum working conditions and to coordinate this work with related and adjacent work.

1.9 WARRANTY

**** NOTE TO SPECIFIER ** Warranty paragraph for Series 418, 422, 426, 432, 416, 429, 424, 430, 511 and 521 commercial sectional doors is 1 Year and covered under General Conditions of Contract.**

**** NOTE TO SPECIFIER ** Include the following warranty paragraph for Thermacore® Series 850, 591, 592, 593, 594, 596, or 599 commercial sectional doors and model RSX®, RMX®, or RHX® commercial door operators provided together as a System.. Delete if not applicable.**

- A. Warranty: Manufacturer's limited door and operators System warranty for 10 year against delamination of polyurethane foam from steel face and all other components for 3 years or 20,000 cycles, whichever comes first.

**** NOTE TO SPECIFIER ** Include the following warranty paragraph for Thermacore® Series 598 commercial sectional doors and model RSX®, RMX®, or RHX® commercial door operators provided together as a System.. Delete if not applicable.**

- B. Warranty: Manufacturer's limited door and operators System warranty for 8 year against delamination of polyurethane foam from steel face and all other components for 3 years or 20,000 cycles, whichever comes first.

PART 2 PRODUCTS

2.1 MANUFACTURERS

- A. Acceptable Manufacturer: Overhead Door Corp., 2501 S. State Hwy. 121, Suite 200, Lewisville, TX 75067. ASD. Tel. Toll Free: (800) 275-3290. Phone: (469) 549-7100. Fax: (972) 906-1499. Web Site: www.overheaddoor.com. E-mail: info@overheaddoor.com.

**** NOTE TO SPECIFIER ** Delete one of the following two paragraphs; coordinate with requirements of Division 1 section on product options and substitutions.**

- B. Substitutions: Not permitted.
- C. Requests for substitutions will be considered in accordance with provisions of Section 01600.

2.2 INSULATED SECTIONAL OVERHEAD DOORS

**** NOTE TO SPECIFIER ** Overhead Door Corporation Model 850 Thermacore® XP Insulated Steel Doors are available up to a maximum width of 40 feet 2 inches and a maximum height of 24 feet 1 inch. Edit as required to suit project requirements.**

- A. Insulated Steel Sectional Overhead Doors: Thermacore AP Model 850 Insulated Steel Doors by Overhead Door Corporation. Units shall have the following characteristics:

1. Door Assembly: Metal/foam/metal sandwich panel construction, with 1-3/4 inch wide PVC thermal break and patents pending weather-tight Dual Barrier tongue-in-groove meeting joints.
 - a. Panel Thickness: 3 inches (76.2 mm).
 - b. Exterior Surface: Microgroove, textured.
 - c. Exterior Steel: .015 inch (.38 mm), hot-dipped galvanized.
 - d. End Stiles: 16 gauge single end stiles provided on doors up to and including 16 feet 2 inches wide; 16 gauge double end stiles provided on doors greater than 16 feet 2 inches wide up to and including 26 feet 2 inches; 14 gauge double end stiles provided on doors greater than 26 feet 2 inches wide. Provide with thermal break to prevent heat/cold transfer.
 - e. Spring Counterbalance: Sized to weight of the door, with a helically wound, oil tempered torsion spring mounted on a steel shaft; cable drum of diecast aluminum with high strength galvanized aircraft cable. Sized with a minimum 7 to 1 safety factor.

**** NOTE TO SPECIFIER ** Select one of the following paragraphs and delete the ones not required. 10,000 cycles are standard.**

- 1) Standard cycle spring: 10,000 cycles.
- 2) High cycle spring: 50,000 cycles.
- 3) High cycle spring: 100,000 cycles.
- f. Insulation: CFC-free and HCFC-free polyurethane, fully encapsulated.
- g. Thermal Values: Calculated R-value of 26; U-value of 0.038.
- h. Installed U-factor: 0.14 Btu/hr/SF degrees F.
- i. Air Infiltration: .09 cfm at 15 mph.
- j. Sound Transmission Rating: STC 22

**** NOTE TO SPECIFIER ** Select the following paragraph if required and delete if not required.**

- k. High-Usage Package: Provide with optional high-usage package.
- l. Partial Glazing of Steel Panels:
 - 1) Standard with black frame:
 - (a) 1/2 inch (12.5 mm) Insulated.
 - (b) 1/2 inch Tempered Insulated.
 - (c) 5/8 inch (15.87 mm) Triple-Wall Polycarbonate (clear, bronze, white).
 - 2) Color matched frame: white, brown, almond, taupe.
 - (a) 1/2 inch (12.7 mm) Tempered Insulated
 - (b) 1/2 inch (12.7 mm) Insulated.

2. Finish and Color:

**** NOTE TO SPECIFIER ** Select one of the following exterior finish and color paragraphs and delete the ones not required.**

- a. Two coat baked-on polyester:
 - 1) Interior color, white.

**** NOTE TO SPECIFIER ** Select one of the following exterior color paragraphs and delete the ones not required.**

- 2) Exterior color, white.
- 3) Exterior color, brown.
- 4) Exterior color, almond
- 5) Exterior color, taupe

**** NOTE TO SPECIFIER ** The following paragraph is optional. Contact the manufacturer for additional information regarding the options available. Include the Design/Performance Requirements in Part 1 of this specification.**

3. Windload Design: Provide to meet the Design/Performance requirements specified.
4. Hardware: Galvanized steel hinges and fixtures. Ball bearing rollers with hardened steel races.
5. Lock:

**** NOTE TO SPECIFIER ** Select one of the following paragraphs and delete the ones not required. Interior mounted slide lock is standard.**

- a. Interior mounted slide lock.
 - b. Interior mounted slide lock with interlock switch for automatic operator.
 - c. Keyed lock.
 - d. Keyed lock with interlock switch for automatic operator.
6. Weatherstripping:

**** NOTE TO SPECIFIER ** Select the seals required from the following paragraphs and delete those not required. Bottom seal and head seals are standard, jamb seal and EPDM bottom seal are optional.**

- a. PVC retainer with dual durometer PVC bulb seal.
 - b. Factory installed Flexible Header seal.
 - c. Optional EPDM bulb seal. Recommended for extreme weather conditions.
 - d. Optional Exclusive Advanced Performance Jamb seals recommended for extreme weather conditions.
7. Track: Provide track as recommended by manufacturer to suit loading required and clearances available.

**** NOTE TO SPECIFIER ** Edit the following track size and type paragraphs as required and delete the ones not required.**

- a. Size:
 - 1) 2 inch (51 mm).
 - 2) 3 inch (76 mm).
- b. Type:
 - 1) Standard lift.
 - 2) Vertical lift.
 - 3) High lift.
 - 4) Low headroom.
 - 5) Follow roof slope.

**** NOTE TO SPECIFIER ** Select one of the following Operation paragraphs and delete the ones not required. Manual pull rope is standard.**

- 8. Manual Operation: Pull rope.
- 9. Manual Operation: Chain hoist.
- 10. Electric Motor Operation: Provide UL listed electric operator, size and type as recommended by manufacturer to move door in either direction at not less than 2/3 foot nor more than 1 foot per second. Operator shall meet UL325/2010 requirements for continuous monitoring of safety devices.
 - a. Entrapment Protection: Required for momentary contact, includes radio control operation.

**** NOTE TO SPECIFIER ** Select one of the following protection paragraphs and delete those not required.**

- 1) Pneumatic sensing edge up to 18 feet (5.5 m) wide. Constant contact only complying with UL 325/2010.
- 2) Electric sensing edge monitored to meet UL 325/2010.
- 3) Photoelectric sensors monitored to meet UL 325/2010.
- b. Operator Controls:

**** NOTE TO SPECIFIER ** Select one of the following control paragraphs and delete those not required.**

- 1) Push-button operated control stations with open, close, and stop buttons.
- 2) Key operated control stations with open, close, and stop buttons.
- 3) Push-button and key operated control stations with open, close, and stop buttons.

**** NOTE TO SPECIFIER ** Select one of the following mounting paragraphs and delete the one not required.**

- 4) Flush mounting.
- 5) Surface mounting.

**** NOTE TO SPECIFIER ** Select one of the following mounting location paragraphs and delete those not required.**

- 6) Interior location.

- 7) Exterior location.
- 8) Both interior and exterior location.

**** NOTE TO SPECIFIER ** Select special operation features from the following paragraphs and delete those not required. Delete entirely if not required.**

- c. Special Operation:
 - 1) Pull switch.
 - 2) Vehicle detector operation.
 - 3) Radio control operation.
 - 4) Card reader control.
 - 5) Photocell operation.
 - 6) Door timer operation.
 - 7) Commercial light package.
 - 8) Explosion and dust ignition proof control wiring.

PART 3 EXECUTION

3.1 EXAMINATION

- A. Do not begin installation until openings have been properly prepared.
- B. Verify wall openings are ready to receive work and opening dimensions and tolerances are within specified limits.
- C. Verify electric power is available and of correct characteristics.
- D. If preparation is the responsibility of another installer, notify Architect of unsatisfactory preparation before proceeding.

3.2 PREPARATION

- A. Clean surfaces thoroughly prior to installation.
- B. Prepare surfaces using the methods recommended by the manufacturer for achieving the best result for the substrate under the project conditions.

3.3 INSTALLATION

- A. Install overhead doors and track in accordance with approved shop drawings and the manufacturer's printed instructions.
- B. Coordinate installation with adjacent work to ensure proper clearances and allow for maintenance.
- C. Anchor assembly to wall construction and building framing without distortion or stress.
- D. Securely brace door tracks suspended from structure. Secure tracks to structural members only.
- E. Fit and align door assembly including hardware.

**** NOTE TO SPECIFIER ** Select the following paragraph for power operated doors. Delete if not required.**

- F. Coordinate installation of electrical service. Complete power and control wiring from disconnect to unit components.

3.4 CLEANING AND ADJUSTING

- A. Adjust door assembly to smooth operation and in full contact with weatherstripping.
- B. Clean doors, frames and glass.
- C. Remove temporary labels and visible markings.

3.5 PROTECTION

- A. Do not permit construction traffic through overhead door openings after adjustment and cleaning.
- B. Protect installed products until completion of project.
- C. Touch-up, damaged coatings and finishes and repair minor damage before Substantial Completion.

END OF SECTION