

The Genuine. The Original.



SECTION 08 36 00
SECTIONAL OVERHEAD DOORS
THERMACORE® INSULATED STEEL DOORS MODEL 515

Display hidden notes to specifier by using 'Tools'/'Options'/'View'/'Hidden Text'. On newer versions of Microsoft Word click on round Windows logo in top left corner, Click on 'Word Options' button at bottom of drop down menu. Click on 'Display' on left menu bar, and check the box for 'Hidden Text'.

**** NOTE TO SPECIFIER ** Overhead Door Corp.; Commercial Sectional Overhead Door products.**

This section is based on the products of Overhead Door Corp., which is located at: 2501 S. State Hwy. 121 Suite 200 Lewisville, TX 75067; Toll Free: (800) 275-3290 Phone: (469) 549-7100 Fax: (972) -906-1499 Web Site: www.overheaddoor.com E-mail: info@overheaddoor.com. [click Here] for additional information.

Overhead Door Corporation pioneered the upward-acting door industry, inventing the first upward-acting door in 1921 and the first electric door opener in 1926. Today, we continue to be the industry leader through the strength of our product innovation, superior craftsmanship and outstanding customer support, underscoring a legacy of quality, expertise and integrity. That's why design and construction professionals specify Overhead Door Corporation products more often than any other brand.

This specification includes Overhead Door Corp. Insulated Sectional Overhead Doors. Contact Overhead Door for support in selecting doors to meet your criteria.

PART 1 GENERAL

1.1 SECTION INCLUDES

**** NOTE TO SPECIFIER ** Delete items below not required for project.**

- A. Insulated Sectional Overhead Doors.
- B. Electric Operators and Controls.
- C. Operating Hardware, tracks, and support.

1.2 RELATED SECTIONS

**** NOTE TO SPECIFIER ** Delete any sections below not relevant to this project; add others as required.**

- A. Section 03300 - Cast-In-Place Concrete: Prepared opening in concrete. Execution requirements for placement of anchors in concrete wall construction.
- B. Section 04810 - Unit Masonry Assemblies: Prepared opening in masonry. Execution requirements for placement of anchors in masonry wall construction.
- C. Section 05500 - Metal Fabrications: Steel frame and supports.
- D. Section 06114 - Wood Blocking and Curbing: Rough wood framing and blocking for door opening.
- E. Section 07900 - Joint Sealers: Perimeter sealant and backup materials.

- F. Section 08710 - Door Hardware: Cylinder locks.
- G. Section 09900 - Paints and Coatings: Field painting.
- H. Section 11150 - Parking Control Equipment: Remote door control.
- I. Section 16130 - Raceway and Boxes: Empty conduit from control station to door operator.
- J. Section 16150 - Wiring Connections: Electrical service to door operator.

1.3 REFERENCES

**** NOTE TO SPECIFIER ** Delete references from the list below that are not actually required by the text of the edited section.**

- A. ANSI/DASMA 102 - American National Standard Specifications for Sectional Overhead Type Doors.

1.4 DESIGN / PERFORMANCE REQUIREMENTS

**** NOTE TO SPECIFIER ** Use the applicable building code to determine the actual loading required and edit the following paragraph accordingly. Coordinate with the manufacturer for the selection of doors to meet the required criteria.**

- A. Wind Loads: Design and size components to withstand loads caused by pressure and suction of wind acting normal to plane of wall as calculated in accordance with applicable code.
 - 1. Design pressure of _____ lb/sq ft (_____ kPa).

**** NOTE TO SPECIFIER ** Edit the following paragraph for power operators as required. Delete if not required.**

- B. Wiring Connections: Requirements for electrical characteristics.
 - 1. 115 volts, single phase, 60 Hz.
 - 2. 230 volts, single phase, 60 Hz.
 - 3. 230 volts, three phase, 60 Hz.
 - 4. 460 volts, three phase, 60 Hz.
- C. Single-Source Responsibility: Provide doors, tracks, motors, and accessories from one manufacturer for each type of door. Provide secondary components from source acceptable to manufacturer of primary components.

1.5 SUBMITTALS

- A. Submit under provisions of Section 01300.
- B. Product Data: Manufacturer's data sheets on each product to be used, including:
 - 1. Preparation instructions and recommendations.
 - 2. Storage and handling requirements and recommendations.
 - 3. Installation methods.
- C. Shop Drawings: Indicate plans and elevations including opening dimensions and required tolerances, connection details, anchorage spacing, hardware locations, and installation details.
- D. Manufacturer's Certificates: Certify products meet or exceed specified requirements.

E. Operation and Maintenance Data.

1.6 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Company specializing in manufacturing products specified in this section with minimum five years documented experience.
- B. Installer Qualifications: Authorized representative of the manufacturer with minimum five years documented experience.
- C. Products Requiring Electrical Connection: Listed and classified by Underwriters Laboratories, Inc. acceptable to authority having jurisdiction as suitable for purpose specified.

1.7 DELIVERY, STORAGE, AND HANDLING

- A. Store products in manufacturer's unopened labeled packaging until ready for installation.
- B. Protect materials from exposure to moisture until ready for installation.
- C. Store materials in a dry, ventilated weathertight location.

1.8 PROJECT CONDITIONS

- A. Pre-Installation Conference: Convene a pre-installation conference just prior to commencement of field operations, to establish procedures to maintain optimum working conditions and to coordinate this work with related and adjacent work.

1.9 WARRANTY

- A. Warranty: Manufacturer's limited door and operators System warranty for 10 year against delamination of polyurethane foam from steel face and all other components for 3 years or 20,000 cycles, whichever comes first.

PART 2 PRODUCTS

2.1 MANUFACTURERS

- A. Acceptable Manufacturer: Overhead Door Corp., 2501 S. State Hwy. 121, Suite 200, Lewisville, TX 75067. ASD. Tel. Toll Free: (800) 275-3290. Phone: (469) 549-7100. Fax: (972) 906-1499. Web Site: www.overheaddoor.com. E-mail: arcat@overheaddoor.com.

**** NOTE TO SPECIFIER ** Delete one of the following two paragraphs; coordinate with requirements of Division 1 section on product options and substitutions.**

- B. Substitutions: Not permitted.
- C. Requests for substitutions will be considered in accordance with provisions of Section 01600.

2.2 INSULATED SECTIONAL OVERHEAD DOORS

**** NOTE TO SPECIFIER ** Overhead Door Corporation 515 Series Insulated Steel Doors are available up to a maximum width of 22 feet 2 inches and a maximum height of 20 feet 1 inch. Edit as required to suit project requirements.**

A. Insulated Steel Sectional Overhead Doors: 515 Series Thermacore Wind Load Insulated Steel Doors by Overhead Door Corporation. Units shall have the following characteristics:

1. Door Assembly: Metal/foam/metal sandwich panel construction, with hot melt thermal break.
 - a. Panel Thickness: 1-3/8 inches (34.92 mm).
 - b. Exterior Surface:

**** NOTE TO SPECIFIER ** Select one of the following exterior surface paragraphs and delete those not required.**

- 1) Microgroove, textured.
- 2) Flush with non-repeating wood grain texture.
- 3) Raised panel with non-repeating wood grain texture.
- c. Exterior Steel: .015 inch (0.38 mm), hot-dipped galvanized.
- d. Ends: Hot-dipped galvanized steel, full height with end caps.

**** NOTE TO SPECIFIER ** Select one of the following paragraphs and delete the ones not required. Delete entirely if gauge is to be determined by PERFORMANCE REQUIREMENTS.**

- 1) 18 gauge.
- 2) 16 gauge.
- e. Spring Counterbalance: Sized to weight of the door, with a helically wound, oil tempered torsion spring mounted on a steel shaft; cable drum of die cast aluminum with high strength galvanized aircraft cable. Sized with a minimum 5 to 1 safety factor.

**** NOTE TO SPECIFIER ** Select one of the following paragraphs and delete the ones not required. 10,000 cycles are standard.**

- 1) High cycle spring: 25,000 cycles.
- 2) High cycle spring: 50,000 cycles.
- 3) High cycle spring: 100,000 cycles.
- f. Thermal Values: R-value of 12.12; U-value of 0.0825.
- g. Air Infiltration: 0.23 cfm at 15 mph.
- h. Sound transmission class 20 when tested in accordance with ASTM E 413.
- i. Outdoor-indoor transmission class 20 when tested in accordance with ASTM E 1332.
- j. Insulation: CFC-free and HCFC-free polyurethane, fully encapsulated.
 - 1) Insulated sections tested in accordance with ASTM E 84 and achieve a Flame spread Index of 10 or less, and a Smoke Developed Index of 210 or less.
 - 2) Insulation material tested in accordance with ASTM D 1929 and achieve a minimum Flash Ignition temperature of 734 degrees F, and a minimum Self Ignition temperature of 950 degrees F.
 - 3) Insulated sections shall meet all requirements of the UBC 17-5 corner burn.

**** NOTE TO SPECIFIER ** Select Thermolite glazing for flush doors or colonial style SSB for raised panel or flush glazing from the following glazing paragraphs and edit to select glazing required. Delete those not required or delete entirely if glazing is not required. Contact the manufacturer if additional requirements are required.**

- k. Partial Glazing of Steel Panels:
 - 1) Thermolite double insulated SSB set in 2-piece high-impact polymer frame.
 - 2) Tempered Thermolite.
 - 3) StyleLine Lite Colonial SSB.
- l. Single Panel Lite:
 - 1) 1/4 inch (6 mm) Tempered glass.

- 2) 1/4 inch (6 mm) Acrylic (Plexiglass) glazing.
- 3) 1/4 inch (6 mm) Polycarbonate (Lexan) glazing.
- 4) 1/4 inch (6 mm) Polished wire glass.
- m. Colonial Style SSB with High Impact Polymer Frame:

2. Finish and Color:

**** NOTE TO SPECIFIER ** Select one of the following finish paragraphs and delete the one not required.**

- a. Two coat baked-on polyester:
 - 1) Interior color, white.

**** NOTE TO SPECIFIER ** Select one of the following exterior color paragraphs and delete the ones not required.**

- 1) Exterior color, white.
- 2) Exterior color, taupe.
- 3) Exterior color, almond.
- 4) Exterior color, brown.
- 5) Exterior color, black

- b. Exterior Bi-Directional Woodgrain Pattern:

**** NOTE TO SPECIFIER ** Select one of the following exterior color paragraphs and delete the ones not required.**

- 1) Exterior color, Oak.
- 2) Exterior color, Dark brown.

**** NOTE TO SPECIFIER ** The following paragraph is optional. Contact the manufacturer for additional information regarding the options available. Include the Design/Performance Requirements in Part 1 of this specification.**

- 3. Windload Design: Provide to meet the Design/Performance requirements specified.
- 4. Hardware: Galvanized steel hinges and fixtures. Ball bearing rollers with hardened steel races.
- 5. Lock:

**** NOTE TO SPECIFIER ** Select one of the following paragraphs and delete the ones not required. Interior mounted slide lock is standard.**

- a. Interior mounted slide lock.
- b. Interior mounted slide lock with interlock switch for automatic operator.
- c. Keyed lock.
- d. Keyed lock with interlock switch for automatic operator.

**** NOTE TO SPECIFIER ** Select the following paragraph for use with knock-out lower door sections only and delete the ones above.**

- e. Locking mechanism designed to maintain security for exterior while permitting break out when impacted from the inside.

6. Weatherstripping:

**** NOTE TO SPECIFIER ** Select the seals required from the following paragraphs and delete those not required. Bottom seal is standard, jamb seals and head seals are optional.**

- a. Flexible bulb-type strip at bottom section.
- b. Flexible Jamb seals.
- c. Flexible Header seal.

7. Track: Provide track as recommended by manufacturer to suit loading required and clearances available.

**** NOTE TO SPECIFIER ** Edit the following track size and type paragraphs as required and delete the ones not required.**

- a. Size:
 - 1) 2 inch (51 mm).
 - 2) 3 inch (76 mm).
- b. Type:
 - 1) Standard lift.
 - 2) Vertical lift.
 - 3) High lift.

- 4) Low headroom.
- 5) Follow roof slope.

**** NOTE TO SPECIFIER ** Select one of the following paragraphs as required and delete the one not required. Horizontal track applies to standard lift, high lift, low headroom and follow-the-roof designs only.**

- c. Horizontal track shall be reinforced with continuous angle of adequate length and gauge to minimize deflection.
- d. Vertical track shall be graduated to provide wedge type weathertight closing with continuous angle mounting for steel or wood jambs, and shall be fully adjustable to seal door at jambs.

**** NOTE TO SPECIFIER ** Select one of the following Operation paragraphs and delete the ones not required. Manufacturer does not recommend chain hoists or jack shaft operators on the following track applications: 15 inch radius standard lift with roof pitch less than 2:12; Hi-Lift less than 24 inch; Low headroom track. Special chain hoist assemblies (using a trolley rail) are available for the above track systems. Special chain hoist assemblies using a trolley rail are available for track systems. Consult manufacturer for additional information.**

8. Manual Operation: Push-up.
9. Manual Operation: Chain hoist.
10. Electric Motor Operation: Provide UL listed electric operator, equal to Genie Commercial Operators, size and type as recommended by manufacturer to move door in either direction at not less than 2/3 foot nor more than 1 foot per second.

**** NOTE TO SPECIFIER ** Select one of the following Duty Type and Model paragraphs and delete those not required.**

- a. Medium Duty
 - 1) Model MH – hoist
 - 2) Model MT – trolley
 - 3) Model MJ - jackshaft
- b. Standard Duty
 - 1) Model H – hoist
 - 2) Model T – trolley
 - 3) Model J – jackshaft
- c. Heavy Duty
 - 1) Model GH – hoist
 - 2) Model GT - trolley
- d. Entrapment Protection: Required for momentary contact, includes radio control operation.

**** NOTE TO SPECIFIER ** Select one of the following protection paragraphs and delete those not required.**

- 1) Pneumatic sensing edge up to 18 feet (5.5 m) wide. Constant contact only complying with UL 325/2010.
- 2) Electric sensing edge monitored to meet UL 325/2010 equal to Miller Edge.
- 3) Photoelectric sensors monitored to meet UL 325/2010.
- e. Operator Controls:

**** NOTE TO SPECIFIER ** Select one of the following control paragraphs and delete those not required.**

- 1) Push-button operated control stations with open, close, and stop buttons.
- 2) Key operated control stations with open, close, and stop buttons.
- 3) Push-button and key operated control stations with open, close, and stop buttons.

**** NOTE TO SPECIFIER ** Select one of the following mounting paragraphs and delete the one not required.**

- 4) Flush mounting.

5) Surface mounting.

**** NOTE TO SPECIFIER ** Select one of the following mounting location paragraphs and delete those not required.**

6) Interior location.

7) Exterior location.

8) Both interior and exterior location.

**** NOTE TO SPECIFIER ** Select special operation features from the following paragraphs and delete those not required. Delete entirely if not required.**

f. Special Operation:

1) Pull switch.

2) Vehicle detector operation.

3) Radio control operation.

4) Card reader control.

5) Photocell operation.

6) Door timer operation.

7) Commercial light package.

8) Explosion and dust ignition proof control wiring.

PART 3 EXECUTION

3.1 EXAMINATION

- A. Do not begin installation until openings have been properly prepared.
- B. Verify wall openings are ready to receive work and opening dimensions and tolerances are within specified limits.
- C. Verify electric power is available and of correct characteristics.
- D. If preparation is the responsibility of another installer, notify Architect of unsatisfactory preparation before proceeding.

3.2 PREPARATION

- A. Clean surfaces thoroughly prior to installation.
- B. Prepare surfaces using the methods recommended by the manufacturer for achieving the best result for the substrate under the project conditions.

3.3 INSTALLATION

- A. Install overhead doors and track in accordance with approved shop drawings and the manufacturer's printed instructions.
- B. Coordinate installation with adjacent work to ensure proper clearances and allow for maintenance.
- C. Anchor assembly to wall construction and building framing without distortion or stress.
- D. Securely brace door tracks suspended from structure. Secure tracks to structural members only.
- E. Fit and align door assembly including hardware.

**** NOTE TO SPECIFIER ** Select one of the following paragraph for power operated doors. Delete if not required.**

- F. Coordinate installation of electrical service. Complete power and control wiring from disconnect to unit components.

3.4 CLEANING AND ADJUSTING

- A. Adjust door assembly to smooth operation and in full contact with weatherstripping.
- B. Clean doors, frames and glass.
- C. Remove temporary labels and visible markings.

3.5 PROTECTION

- A. Do not permit construction traffic through overhead door openings after adjustment and cleaning.
- B. Protect installed products until completion of project.
- C. Touch-up, damaged coatings and finishes and repair minor damage before Substantial Completion.

END OF SECTION